

Parameter	Min	Average	Max	Units	Regulatory	Samples	%Failed
2,4-D	<0.0028	<0.0099	<0.0130	µg/l	0.1	33	0
2,4-DB	<0.0100	<0.0100	<0.0100	µg/l	0.1	3	0
Aluminium	<2.45	<9.07	<33.7	µg Al/l	200	34	0
Ammonium (ammonia and ammonium ions)	<0.0077	<0.0077	<0.0077	mg NH ₄ /l	0.5	9	0
Antimony	<0.140	<0.154	0.240	µg Sb/l	5	7	0
Arsenic	0.0400	0.146	0.370	µg As/l	10	7	0
Benzene	<0.0471	<0.0539	<0.157	µg/l	1	65	0
Benzo(a)pyrene	<0.0010	<0.0011	<0.0020	µg/l	0.01	10	0
Boron	0.0029	<0.0128	0.0302	mg B/l	1	61	0
Bromate	<0.0910	<0.222	0.860	µg BrO ₃ /l	10	6	0
Cadmium	<0.0300	<0.0329	0.0500	µg Cd/l	5	7	0
Calcium	8.70	26.4	62.7	mg Ca/l		34	0
Carbetamide	<0.0100	<0.0100	<0.0110	µg/l	0.1	31	0
Chloride	7.48	20.6	41.4	mg Cl/l	250	62	0
Chromium	0.0700	0.123	0.180	µg Cr/l	50	7	0
Residual chlorine - Total	0.11	0.64	1.02	mg/l		75	0
Residual chlorine - Free	0.05	0.57	0.82	mg/l		76	0
Chlortoluron	<0.0100	<0.0100	<0.0100	µg/l	0.1	25	0
Colony counts after 3 days at 22 deg C	0	1	14	number/1ml		31	0
Coliform bacteria	0	0	7	number/100ml	0	74	2.7
Colour	<0.370	<0.722	<2.16	mg/l Pt/Co scale	20	35	0
Conductivity	93.6	258	552	uS/cm at 20oC	2500	33	0
Copper	0.0018	0.0192	0.102	mg Cu/l	2	8	0
Clostridium perfringens (including spores)	0	0	0	number/100ml	0	6	0
Clopyralid	<0.0080	<0.0111	0.0300	µg/l	0.1	35	0
Cyanide	<0.698	<1.16	<2.33	µg CN/l	50	64	0
1,2-dichloroethane	<0.138	<0.158	<0.459	µg/l	3	63	0
Diazinon	<0.0100	<0.0100	<0.0100	µg/l	0.1	10	0
Dicamba	<0.0100	<0.0110	<0.0190	µg/l	0.1	9	0
E.coli	0	0	0	number/100ml	0	74	0
Enterococci	0	0	0	number/100ml	0	6	0
Fluoride	0.0100	<0.0316	0.0800	mg F/l	1.5	126	0
Fluroxypyr	<0.0023	<0.0100	<0.0160	µg/l	0.1	35	0
Glyphosate	<0.0090	<0.0090	<0.0090	µg/l	0.1	34	0
Hardness Total as CaCO ₃	25	82	188	mg CaCO ₃ /l		34	0

Parameter	Min	Average	Max	Units	Regulatory	Samples	%Failed
Iron	<2.82	<27.7	127	µg Fe/l	200	34	0
Lead	<0.290	<0.573	1.89	µg Pb/l	10	8	0
Linuron	<0.0100	<0.0101	<0.0120	µg/l	0.1	25	0
Magnesium	0.880	3.95	9.00	mg Mg/l		34	0
Manganese	0.340	<0.916	4.38	µg Mn/l	50	34	0
MCPA	<0.0033	<0.0100	<0.0120	µg/l	0.1	34	0
Mecoprop	<0.0100	<0.0100	0.0100	µg/l	0.1	34	0
Mercury	<0.0150	<0.0188	<0.0400	µg Hg/l	1	56	0
Metazachlor	<0.0100	<0.0101	<0.0110	µg/l	0.1	26	0
Metaldehyde	<0.0100	<0.0101	0.0110	µg/l	0.1	32	0
Nickel	<0.310	<1.06	1.84	µg Ni/l	20	8	0
Nitrite	<0.0016	<0.0016	<0.0016	mg NO2/l	0.5	7	0
Nitrate	0.930	7.55	20.5	mg NO3/l	50	7	0
(Nitrate)/50 plus (nitrite)/3	0.0180	0.151	0.412	mg/l	1	7	0
Odour (quantitative)	0	0	0	dilution number at 25oC	0	33	0
Total organic carbon	0.210	1.30	3.01	mg C/l		63	0
Polycyclic aromatic hydrocarbons (sum of 4 PAHs)	0.0000	0.0001	0.0010	µg/l	0.1	9	0
Pesticides - Total	0.0000	0.0045	0.0809	µg/l	0.5	129	0
Hydrogen ion (pH)	6.82	7.28	7.58	pH value	9.5	52	0
Propyzamide	<0.0100	<0.0100	<0.0110	µg/l	0.1	25	0
Selenium	<0.0500	<0.141	0.410	µg Se/l	10	7	0
Sodium	9.40	37.7	55.6	mg Na/l	200	6	0
Sulphate	17.7	41.1	143	mg SO4/l	250	66	0
Taste (quantitative)	0	0	0	dilution number at 25oC	0	33	0
Tetrachloromethane	<0.0152	<0.0278	0.0800	µg/l	3	8	0
Trihalomethanes - Total	7.36	28.1	51.7	µg/l	100	8	0
Triclopyr	<0.0080	<0.0108	<0.0200	µg/l	0.1	10	0
Tetrachloroethene and trichloroethene	0.0000	0.0000	0.0000	µg/l	10	8	0
Turbidity	<0.05	<0.08	<0.24	NTU	4	35	0

United Utilities Group PLC

Haweswater House
Lingley Mere Business Park
Lingley Green Avenue
Great Sankey
Warrington
WA5 3LP

**ACCESSIBILITY
HELP?**